

# Submittal Data Sheet - TS Standard Electro-Boiler™

## PROJECT INFORMATION

Job Name: \_\_\_\_\_

Part No. Ordered: \_\_\_\_\_

Location: \_\_\_\_\_

PO Number: \_\_\_\_\_

Engineer: \_\_\_\_\_

Date Submitted: \_\_\_\_\_

Contractor: \_\_\_\_\_

Mfg. Rep: \_\_\_\_\_

## STANDARD EQUIPMENT

### Staging - EB-S-\*\*

- Supply water sensing
- Regulates to front panel selected temperature
- Staging indicator lights
- DC Power Relays
- Hi-limits: 1<sup>st</sup> - automatic reset at 190° F  
2<sup>nd</sup> - manual reset at 205° F
- Circulator switching relay - 10-amp maximum
- Thermostat or end switch connection (R and W)
- Utility load control provisions
- 6.5 gl. Steel vessel ASME "H" Stamp (20-year warranty)
- Supply temperature/pressure gauge

- Safety relief valve (30 PSI)
- Optional standby boiler control kit, plug-in
  - Standby switch and boiler contact

### Modulating - EB-WA-\*\*

- Same as EB-S-\*\* PLUS
- Modulates at a tighter temperature control
- Standby control package

### Modulating - EB-WO-\*\*

- Same as EB-WA-\*\* PLUS
- Outdoor sensing with outdoor reset capability. The target supply temperature ramps up as it is colder outside.

## WATER FLOW REQUIREMENTS

Model	Water Temperature Rise											
	Flow - 10° F/6° C		Head Loss		Flow - 20° F/11° C		Head Loss		Flow - 30° F/16° C		Head Loss	
	gpm	lpm	ft	m	gpm	lpm	ft	m	gpm	lpm	ft	m
EB-**-13	9.21	34.86	.03	.009	4.60	17.41	.01	.003	3.07	11.62	.004	.001
EB-**-18	12.28	46.49	.06	.018	6.14	23.24	.02	.006	4.09	15.48	.01	.003
EB-**-23	15.35	58.11	.09	.027	7.67	29.03	.02	.006	5.11	19.34	.01	.003
EB-**-27	18.43	69.77	.13	.039	9.21	34.86	.03	.009	6.14	23.24	.02	.006
EB-W*-13-2	9.21	34.86	.03	.009	4.60	17.41	.01	.003	3.07	11.62	.004	.001
EB-W*-27-2	18.43	69.77	.13	.039	9.21	34.86	.03	.009	6.14	23.24	.02	.006

\*\* = S, WA, or WO

Note: Head Loss based on 110° F return temperature.

## ELECTRIC SUPPLY

Model	Volts	Watts	Amps	kW	Phase	Btu/h	CB
EB-**-13	240	13,500	56	13.5	1-60	46,075	60 + 30
EB-**-18	240	18,000	75	18	1-60	61,434	60 + 60
EB-**-23	240	22,500	94	22.5	1-60	76,792	60 + 60 + 30
EB-**-27	240	27,000	113	27	1-60	92,151	60 + 60 + 60
EB-W*-13-2	208	13,500	37.5	13.5	3-60	46,075	50
EB-W*-27-2	208	27,000	75	27	3-60	92,151	100

\*\* = S, WA, or WO



Specifications subject to change without notice,  
all rights reserved.

## CLEARANCES

	MINIMUM CLEARANCE FROM COMBUSTIBLE SURFACES		SUGGESTED MINIMUM SERVICE CLEARANCE	
BACK	0 INCH	0 MM	0 INCH	0 MM
LEFT	1 INCH	25 MM	12 INCHES	305 MM
RIGHT	1 INCH	25 MM	6 INCHES	152 MM
FRONT	1 INCH	25 MM	24 INCHES	610 MM
TOP	1 INCH	25 MM	24 INCHES	610 MM
BOTTOM	REQUIRED CLEARANCE - 16 INCHES/406 MM			



ELECTRO INDUSTRIES, INC.

2150 West River Street, PO Box 538, Monticello, MN 55362  
763.295.4138 • 800.922.4138 • fax 763.295.4434  
sales@electromn.com • www.electromn.com

# Electro-Boiler EB-S/EB-W\* series

DIMENSIONS ARE: MM  
IN.

Hydronic Boilers  
Submittal Data

