

## SUBMITTAL COVER SHEET

### JIM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

#### MODEL SUMMARY

Quantity		Clear Tube	Opaque Tube	
<b>Model</b>	<b>JM-30</b>	<b>1009</b>	<b>1010</b>	
<b>Part #</b>				
<b>Rating BTU</b>	<b>2,001-2,000 MBH</b>	<b>Yes</b>	<b>Yes</b>	
<b>Rating GPH</b>	<b>24.0 Max. GPH</b>	<b>Yes</b>	<b>Yes</b>	
<b>Inlet Port Size</b>	<b>.75" Socket or Barb</b>			
<b>Outlet Port Size</b>	<b>.75" Socket or Barb</b>			
<b>Clear Tube</b>		<b>Yes</b>	<b>No</b>	
<b>Opaque Tube</b>		<b>NO</b>	<b>Yes</b>	
<b>Voltage</b>	<b>N/A</b>			
<b>Amps</b>	<b>N/A</b>			
<b>Watts</b>	<b>N/A</b>			

<b>Pump rating</b>	<b>Shur-Flo</b>	<b>N/a</b>		
<b>pH Panel Model</b>	<b>Walchem</b>	<b>N/A</b>		
<b>Pump panel Model</b>	<b>Heatimer</b>	<b>N/A</b>		
<b>Tube Material</b>	<b>PVC Sch40</b>	<b>Yes</b>		
<b>Tank Material</b>	<b>Polypropylene</b>	<b>N/A</b>		
<b>Tube Temperature Rating</b>	<b>140F Con.</b>	<b>Yes</b>		
<b>Tank Frames</b>	<b>Powder coated</b>	<b>N/A</b>		
<b>Mounting</b>	<b>Horizontal Floor or Wall</b>	<b>Yes</b>		
<b>Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains</b>	<b>Yes</b>			
<b>Common Stack / Boiler</b>	<b>Yes</b>			

**NOTES:**

<p>Recommended Piping: Sch40 PVC, CPVC, Stainless Steel Poly stranded Tubing with clamps</p>
--

**Submitted By:**